

BUREAU OF FIRE PREVENTION
Phone: (732) 244-7400 Ext. 1236

627 Pinewald-Keswick Road
PO Box B
Bayville, NJ 08721


BERKELEY



TOWNSHIP

SMOKE & CARBON MONOXIDE ALARM ANNOUNCEMENT

Be aware of uncertified or recalled detectors/alarms before purchasing. There are a few ways to check the detector's date and UL listing. One way is to look for a label or stamp on the smoke detector that indicates the date of manufacture and/or the device's expiration date. Some devices also have a label to indicate that the device has been tested and listed by Underwriters Laboratories (UL). This label will include the UL logo and a listing number. Many detectors come with a manual that includes information about the manufacture date, expiration date and UL listing.



Smoke Alarms:

- Shall be installed, tested and maintained in accordance with NFPA 72.
- Shall be listed in accordance with ANSI/UL 217.
- Shall be installed on each sleeping level of the premises and outside each sleeping area in the immediate vicinity.

Carbon Monoxide Alarms:

- May be battery-operated, hard-wired or plug-in type and shall be listed by UL 2034
- Shall be installed by the requirements of the New Jersey Uniform Fire Code and NFPA 720.
- Carbon Monoxide Alarms can be mounted at any height on the wall or ceiling.
- Shall be installed and maintained in the immediate vicinity of the sleeping areas.

If you have any questions or concerns regarding a smoke alarm or carbon monoxide alarm, please call our office at 732-244-7400 Ext. 1236. We will be happy to assist you.